

## Major Event Day: February 10, 2026 Alectra Utilities

### 2.1.4.2.10 Major Event Response Reporting

'Major Event' is defined under section 2.1.4.2 of the [Electricity Reporting and Record Keeping Requirements \(RRR\)](#).

When a distributor determines an outage was caused by a Major Event, it shall file a report with the OEB that outlines the distributor's response to the Major Event, including answers to all the questions set out below.

A distributor shall file this report with the OEB within 60 days of the end of the Major Event unless there are exceptional circumstances, in which case the report can be filed within 90 days of the end of the Major Event.

#### Prior to the Major Event

1. Did the distributor have any prior warning that the Major Event would occur?  
 Yes  No

**Additional Comments:**

**On February 10, 2026, numerous sustained outages and momentary interruptions occurred in Alectra Utilities Corporation's (Alectra) service territory as a result of Adverse Environment (Salt/Contamination). Impacts were most prevalent in the City of Vaughan within the PowerStream Rate Zone. Staff were called out to attend to the outages and restore power in a timely manner.**

2. If the distributor did have prior warning, did the distributor arrange to have extra employees on duty or on standby prior to the Major Event beginning?  
 Yes  No

Brief description of arrangements or explain why extra employees were not arranged:

**N/A**

3. If the distributor did have prior warning, did the distributor issue any alert to the public warning of possible outages resulting from the pending Major Event?  
 Yes  No

## Major Event Day: February 10, 2026 Alectra Utilities

### Additional Comments:

N/A

4. Did the distributor train its staff on the response plans to prepare for this type of Major Event?

Yes  No

### During the Major Event

1. Please identify the main contributing Cause of the Major Event as per the table in section 2.1.4.2.5 of the Electricity Reporting and Record Keeping Requirements.

Loss of Supply  
 Lightning  
 Adverse Weather-Wind  
 Adverse Weather-Snow  
 Adverse Weather-Freezing rain/Ice storm  
 Adverse Environment-Fire  
 Adverse Environment-Flooding  
 Other (Adverse Environment)

Please provide a brief description of the event. If the event was caused by weather conditions, please specify the type of weather involved – such as high winds, freezing rain, tornadoes, ice storms, blizzards, heavy rainfall, flooding, or lightning storms.

**On February 10, 2026, a total of 17 sustained outages and 19 momentary interruptions occurred in Alectra’s service territory. The PowerStream Rate Zone was the primary area impacted, accounting for ten (10) sustained outages and nine (9) momentary interruptions, including four (4) sustained outages and five (5) momentary interruptions experienced within the City of Vaughan.**

**Impacts were driven by three distinct major outage events which occurred at various times of the day on February 10. The first of three major outages began at 4:56 a.m., followed by subsequent outages at 7:03 a.m. and 4:36 p.m.**

## Major Event Day: February 10, 2026 Alectra Utilities

The three major outage events collectively represented 89.6% of the total Customer Hours of Interruption (CHI) which occurred on February 10 across Alectra's service territory. Events in the Powerstream Rate Zone accounted for 98.9% of the daily total CHI. Adverse Environment was identified as the primary cause of outages. Specifically, customers served by the Greenwood T.S. and Lazenby T.S.2 suffered from insulator flashovers caused by the heavy accumulation of road salt and other environmental contaminants.

**Alectra took prompt action by accelerating the insulator washing program.**

2. Was the IEEE Standard 1366 used to derive the threshold for the Major Event?
- Yes, used IEEE Standard 1366\*
- No, used IEEE Standard 1366 2-day rolling average
- No, used fixed percentage (i.e., 10% of customers affected)

\*The OEB preferred option

3. When did the Major Event begin (date and time)?

**February 10, 2026 – 4:56 a.m.**

4. If the Major Event was not caused by adverse weather, did the distributor issue any information about this Major Event, such as estimated times of restoration, to the public during the Major Event?

Yes  No

If yes, please provide a brief description of the information. If no, please explain:

**Alectra issued multiple notices via social media channels X (formerly known as Twitter) and Facebook. In addition, Alectra responded to customers' inquiries through direct messaging on Facebook and X. Social media response and updated ETRs to customers were ongoing until the power supply was fully restored.**

**The Communications team also responded to requests from media, such as the Toronto Star, to keep them apprised of outage and restoration updates.**

## Major Event Day: February 10, 2026 Alectra Utilities

**Additionally, Alectra posted safety messages to customers via X and Facebook. The messages included information for customers on reporting an outage through the Contact Centre by phone, website forms and web chat, as well as safety and emergency preparedness messages.**

5. How many customers were interrupted during the Major Event?

**27,266 customers experienced sustained outages on February 10, 2026.**

What percentage of the distributor's total customer base did the interrupted customers represent?

**Interrupted customers represent 2.5% of Alectra's customer base on February 10, 2026. Supply to 90% of the customers affected for each of the three events was restored within approximately 3.5 hours.**

6. How many hours did it take to restore 90% of the customers who were interrupted?

**3.5 hours**

7. How many customers experienced service interruptions lasting less than 24 hours?

**27,266**

8. How many customers experienced service interruptions lasting between 24 and 48 hours?

**0**

9. How many customers experienced service interruptions lasting between 48 and 96 hours?

**0**

10. How many customers experienced service interruptions lasting between 96 and 168 hours?

## Major Event Day: February 10, 2026 Alectra Utilities

0

11. How many customers experienced service interruptions lasting over 168 hours?

0

12. Were there any outages associated with Loss of Supply during the Major Event?  
 Yes  No

If yes, please report on the duration and frequency of the Loss of Supply outages:

**N/A**

13. In responding to the Major Event, did the distributor utilize assistance through a third-party mutual assistance agreement with other utilities?

Yes  No

Do not have third party mutual assistance agreements with other utilities

If yes, please provide the name of the utilities who provided the assistance?

\_\_\_\_\_

14. Did the distributor run out of any needed equipment or materials during the Major Event?

Yes  No

If yes, please describe the shortages: \_\_\_\_\_

15. Provide the following characteristics of the Major Event:

i. Total number of feeders interrupted during the course of the event:  
18

ii. The maximum number of customers that were concurrently without power at any point during the event: 15,289

16. What is the total number of damage assessments performed by the distributor during the course of the event?

**Alectra performed 17 damage assessments.**

## Major Event Day: February 10, 2026 Alectra Utilities

17. What percentage of damage assessments were completed:
- |      |   |             |
|------|---|-------------|
| i.   | Within 4 hours after the interruption began:  | <u>100%</u> |
| ii.  | Within 8 hours after the interruption began:  | <u>0%</u>   |
| iii. | Within 12 hours after the interruption began: | <u>0%</u>   |
| iv.  | Over 12 hours after the interruption began:   | <u>0%</u>   |
18. What communication methods were used to inform customers during the Major Event? Select all that apply:
- Distributor's website
  - Social media
  - Email
  - Text message
  - Telephone line
  - Radio broadcast
  - Other (Toronto Star)
19. During the Major Event, did any of the communication methods used become unavailable? If so, identify which one(s).

**No communication methods became unavailable during the major event.**

20. Provide SAIDI and SAIFI values for this Major Event.
- Daily SAIDI – 2.184 minutes**  
**Daily SAIFI – 0.044**

### After the Major Event

1. What actions, if any, will be taken to be prepared for, or mitigate, such Major Events in the future?
- No further action is required at this time
  - Additional staff training
  - Process improvements
  - System upgrades
  - Other

#### **Additional Comments:**

**The insulator washing program, which has historically included only porcelain insulators, will be extended to include polymeric insulators to mitigate the risk of pole fires.**